

Dated: 01-20-04

**ADDENDUM NO. 4**

**NORTH 48<sup>TH</sup> STREET TRANSFER STATION  
SPECIFICATION NO. 04-015  
CITY OF LINCOLN PROJECT NO. 701293**

Notice to Bidders:

Expansion Joints:

Expansion Joints will be required between each segment of the retaining wall.  
The 6" center bulb type rubber water stops shall be 3/8" thick.

Please attach Addendum No. 4 to the inside cover of your bid proposal as evidence that Addendum No. 4 has been received and sign, date and fax this sheet back to Tim Farmer at (402)-483-1722 as proof the Addendum has been received. Failure to do so could result in rejection of your bid.

\_\_\_\_\_  
Contractor

\_\_\_\_\_  
Date

La04-37